


No. F6 DFS MS/School/SZ/2021/ 630

Dated: 24/8/21

FIRE SAFETY CERTIFICATE

Certified that Sri Guru Tegh Bahadur Khalsa Boys/Girls Sr. Secondary School located at Dev Nagar, Karol Bagh, New Delhi- 110005 is comprised of ground plus two upper floors, using ground and first floor as boys school and second floor as girls school was inspected by the officer concerned of this department on 05.08.2021 in presence of Smt. Parvinder Kaur, Principal of the girls school and found that the said School building have deemed complied with the fire prevention and fire safety requirements in accordance with the Directorate of Education circular No. F 6 Estate/CC/Fire Safety/2011/3298 to 3398 dated 01-03-2011 and that the school building is fit for occupancy class "Educational" with effect from the date of issue of this certificate for a period of three years, subject to compliance of the under mentioned conditions.

Issued on 24/8/21 at New Delhi by.



(Mul. D. S.)
Director
Delhi Fire Service


Copy to:

1. The Principal, Sri Guru Tegh Bahadur Khalsa Boys/Girls Sr Secondary School, Ramjas Lane-1, Karol Bagh, New Delhi- 110005.
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi- 110054

Conditions for the Validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. Basement used only for storage purpose as per BBL.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in


Principal
S. G. T. B. Khalsa Girls
Senior Secondary School
Dev Nagar, New Delhi-110005


Chairman
S. G. T. B. Khalsa Girls
Senior Secondary School
Dev Nagar, New Delhi-110005